

## Propane Conversion Kit Instructions

For G124X SP/DP – Model Boilers

This kit and instructions are for converting the G124 X SP/DP– Model Boilers from Natural Gas to Propane.


### REQUIRED INPUT RATES

G 124 X-18 74, 000 BTU/HR	G 124 X-25 103, 000 BTU/HR	G 124 X-32 132, 500 BTU/HR
------------------------------	-------------------------------	-------------------------------

### WARNING

This conversion kit shall be installed by a qualified service agency in accordance with the manufacturer's instructions and all applicable codes and requirements of the authority having jurisdiction. If the information in these instructions is not followed exactly, a fire, explosion or production of carbon monoxide may result causing property damage, personal injury or loss of life. The qualified service agency performing this work assumes responsibility for the proper conversion of this appliance with this kit.

**CAUTION:** The gas supply shall be shut off prior to disconnecting the electrical power, before proceeding with the conversion.



**Notice:** This manual must be retained for future reference!